



# FIRE DEPARTMENT PREVENTION BUREAU

3500 APRON AVE  
ATWATER, CA 95301  
OFFICE (209) 385-7347

MIKE VAN LOBEN SELS  
Fire Chief  
(209) 966-3622

MARK PIMENTEL  
Division Chief  
(209) 385-7450

## Fireworks Stand Inspection Checklist

Organization \_\_\_\_\_ Contact # \_\_\_\_\_

Stand Address \_\_\_\_\_

Storage Address \_\_\_\_\_

Distributor \_\_\_\_\_ Contact # \_\_\_\_\_

Inspected by \_\_\_\_\_ Date \_\_\_\_\_

### **Each fireworks stand must have the following posted prior to the initial inspection:**

- State Fire Marshal's license
- Merced County Fire Department permit & SRA Map
- Temporary Seller's Permit from the State Board of Equalization
- Certificate of Insurance
- Name and contact information of two people responsible for the operation of the fireworks stand

### **Each fireworks stand must be at least 20 feet from the following:**

- Parking – Block off parking prior to initial inspection
- Public sidewalk or roadway
- Adjacent buildings
- 10Ft from curb line as per MCC 9.26

### **The fireworks stand must be at least 30 feet from the following:**

- Property line
- Fireworks storage container
- Generators or associated fuel supplies

### **The fireworks stand must be at least 100 feet from the following:**

- Any pump, dispensing devise, or fill location for flammable and/or combustible liquids and/or gases
- 50 Ft from burnable materials, including dry vegetation

### **Other fireworks stand requirements:**

- Each end of the booth shall have an exit and each stand will have a minimum of 2 exits. Each exit must have a minimum 32" wide clear width.
- Only electric lights may be used and the wiring shall meet the minimum requirements of the California Electrical Code. All exposed bulbs must be covered.
- Red lettered "NO SMOKING" signs shall be located on all sides of the stand. (In both English and Spanish).
- One approved 2A:10BC or one 2 ½ gallon water type portable fire extinguisher must be in the stand sale area and must be serviced within the last year.
- Fireworks signs, sandwich boards, and advertisements shall be limited to the booth and no more than 30' surrounding the booth.
- All persons within the fireworks stand or employed in the sales must be at least 18 years of age.
- Stands may not obstruct any handicapped parking stall.
- Display at least 1 of each product for initial inspection.
- No alcoholic beverages in/around stand.